

c/12



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/WZ/School/2025/ 371

Dated: 13/05/2025

To,

The Principal,  
M. C. Primary Boys School,  
D-Block, Rajiv Nagar-II,  
Delhi-110086.

**Sub:** Issuance of Fire Safety Certificate in r/o M. C. Primary Boys School, D-Block, Rajiv Nagar-II, Delhi-110086.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 252 dated 04.04.2025 on the subject cited above. In this connection it is to inform you that the building was visited by officer of this department on dated 29.04.2025 & it has been observed that the shortcoming already issued by this department letter of even No. 2468 dated 30.10.2013 is not yet rectified (Copy enclosed). Therefore, you are advised to submit point 30.10.2013 for further consideration in this matter.

Yours Faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

de  
ay

C/S

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

**NO. F-6/DFS/MS/2013/** *School/2468*

**Date:** *30/10/2013*

To

The Principal,  
M C Primary Pratibha Vidyalaya,  
D-Block, Rajeev Nagar,  
Delhi-110086

**Sub:** -Regarding fire safety certificate in respect of M C Primary Pratibha Vidyalaya, D-Block,  
Rajeev Nagar, Delhi-110086  
Sir,

Please refer to your letter no. nil dated 29/08/2013 on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 27/09/2013 from fire safety point of view and following shortcomings were observed.

1. The four classrooms where no. of students is more than 45 students require two door of one meter width each. Provide one additional exit of one mtr width in four classrooms.
2. First hose reel required to be provided at each floor.
3. One fire pump of 450 LPM with 40 m head is required to be provided at terrace.
4. Over head water storage tank of 10,000 ltr capacity is required to be provided.

Keeping in view of the above fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the circular of Director of Education issued vide letter No F-16/estate/cc/fire safety/2011/3298-3398 dated 01/03/2011.

Yours faithfully

*u*  
*29/10*

(VIPIN KENTAL)  
Dy Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23846352  
[dcfondz.dlfire@nic.in](mailto:dcfondz.dlfire@nic.in)

*qca*

Copy to:

1. The Additional Director (Admn.), North MCD, Civic Centre, Delhi for information