



C 27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6/DFS/MS/2025/School/WZ/ 1027

Dated: 20/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **M. C. Primary Co-ed School, Rohini, Sector-22, Delhi-110086**, comprised of **Ground + One upper floor** owned/occupied by **M. C. Primary Co-ed School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2021/School/WZ/713** dated **06.09.2021**. The premises was re-inspected by the officer concerned of this department on **09.07.2025** in the presence of **Mr. Satish Malik (In-charge)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education** letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 20/08/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 20/08/2025 at New Delhi

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Principal, M. C. Primary Co-ed School, Rohini, Sector-22, Delhi-110086.
2. The Director, Education, North MCD, Civic Center, New Delhi

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule  
s/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/) [http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : M. C. Primary Co-ed School, Rohini, Sector-22, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + one upper floor**)
4. Details of Previous NOC : F.6/DFS/MS/2021/School/WZ/713 dated 06.09.2021
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 09.07.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers : Mr. Satish Malik (In-charge)
9. Year of Construction : 2012
10. Applicant's letter No. : OD No.3202 dated 30.06.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Cir. of Dir. Of Education	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 4.5m -NA-	Accessible Accessible -NA-	MR MR -NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	01nos. -NA-	01nos. -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.5m -NA-	1.52m -NA-	MR -NA-
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	-NA- 12 a/c per hour	-NA- Natural ventilated	-NA- MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	04nos. ABC/CO2 ISI marked	04nos. ABC-4 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-



0

Special Fire Protection System for  
Protection of special Risks, if any:

-NA-

-NA-

-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2021/School/WZ/713 dated 06.09.2021** is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]* 11/8/25

Signature of the Inspecting Officer

Name Ajay Kumar Sharma

Designation ADO(Rohini)

DO (NW)

DCFO: 239-NW

Dated: 5.8.2025

*[Signature]*  
04/08/2025

*[Signature]*  
24/08/2025

*[Signature]*  
8/8

CFD/  
*[Signature]*  
11/8/2025

Principal Director

CFD to Issue.

*[Signature]*  
13/08/25

ADD(Rohini)

CFD/  
*[Signature]*  
19/8/2025

FT letter is put up for kind perusal and signature please.

*[Signature]*  
18/8/25

CFD/  
*[Signature]*  
19/8/2025

MS