

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-3

No. F6/DFS/MS/School/NDZ/2025/287

Dated: 25/04/2025

To

The Head of School,
M.C. Primary School,
Shiv Vihar (Boys), Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o M.C. Primary School, Shiv Vihar (Boys), Delhi-110094.

Sir,

This has reference to your letter No. Nil dated 09/04/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 23/04/2025 in the presence of Mr. Manoj Kumar (HOS) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor, 1st Floor, 2nd Floor & 3rd Floor**. Following shortcomings were observed during the inspection:-

1. Hose reel hose is provided but nonfunctional.
2. Fire Pump of capacity 450LPM not provided.
3. Overhead tank of capacity 8,000ltr provided against requirement of 10,000 ltr.
4. Exit signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home_Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Forms

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.