

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/SCH/627
 To,

Dated: 11 / 08 / 2025

The Principal,
 M.C. Primary Girls School,
 Subhadra Colony, Delhi- 110035.

Sub: - Inspection report in r/o M.C. Primary Girls School located at Subhadra Colony, Delhi- 110035.

Sir,


This is in reference to your letter no. nil received through outdoor diary no. 2204 dated 28/05/2025 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 17/07/2025 in the presence of Smt. Azra Begum (Principal) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/School/2015/1286 dated 16/06/2015.

The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	Only one staircase of 1.27 m width is provided. The width of staircase should be increase to 1.5 m or an additional staircase of not less than 0.75 m width should be provided.	Not Rectified
2.	Width of class rooms doors are varies from 92 cm to 100 cm against required minimum 100 cm clear width.	Not Rectified
3.	Terrace pump of 450 lpm not provided.	Not Rectified
4.	Overhead tank of 10,000 ltrs not provided.	Rectified
5.	Exit sign not provided.	Not Rectified
6.	LPG cylinder are being used without precaution it should be as per DOE circular dated 01/03/2011.	No LPG Cylinder found used
7.	Hose Reel found non functional.	Not Rectified
8.	Electric wiring should be concealed type.	Not Rectified
9.	Electric meter has been installed under the stairs.	Not Rectified

In view of the above **shortcomings**, the request for issuance of Fire Safety Certificate can't be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this regard.

Yours faithfully,


 5/8/2025
 (Virendra Singh)
 Chief Fire Officer
 olea

Copy to:-

1. The Director, Directorate of Education, MCD, Civic Centre, Delhi.