

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

c 23

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 83

Dated: 30/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C. Pr. School, located at Tulsi Nagar, Delhi-110035, comprised of G + 01 Upper floor Only, was issued FSC vide letter No F6/DFS/MS/School/WZ/2021/553 dated 29/07/2021. The premises was re - inspected by the officer concerned by this department on 21/01/2025 in the presence of Sabiha Rasheed (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition & that the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with D.O.E Circular No. 3298-3398 dated 01/03/2011 and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 30/01/2025 for a period of three years subject to compliance of the Condition mentioned below.

Issued on 30/01/2025 at New Delhi.

(Anil Garg)
Director

Copy to:

1. The Principal, M.C. Pr. School, Located at Tulsi Nagar, Delhi-110035.

Email- tulsinagargirls.cczmcd@gmail.com

2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

12/14
INSPECTION REPORT

1.	Name & address of the building	M.C. Pr. School, Located at Tulsi Nagar, Delhi-110035.
2.	Type of Occupancy	Educational (G + 01 Upper floor Only)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2021/553 dated 29/07/2021.
5.	Fire Safety directives letter No	DOE Circular No. 3298-3398 dated 01/03/2011.
6.	Date of inspection	21/01/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sabiha Rasheed (Principal)
9.	Year of Construction	2013 (As per previous Inspection Report)
10.	Applicant's letter No.	Email dated 27/11/2024.

The School is running in a Building comprised of G + 01 Upper floor Only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	436cm	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	150cm	1 x 150cm, 1 x 153cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5m	221cm	MR
	f. Door Size	100cm	111cm	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	07 nos.	8 nos. Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

8/2

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA

r/16

18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2021/553 dated 29/07/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Dy CPO/WZ
[Signature]

[Signature]
24/1/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

20/1/2025
10/1/2025

[Signature]
24/1/2025

[Signature]
27/01/2025

[Signature]
28/1/25

[Signature]

Sir F. T is put up for your kind personal & signature please.

[Signature]
29/1/2025

[Signature]
30/1/25