

C/28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/NDZ/2025/ 483

Dated: 06/06/2025

To

The Principal,
M.C. Primary Co-Ed School,
Turkman Gate, Delhi - 110006.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M.C. Primary Co-Ed School, Turkman Gate, Delhi - 110006.


Sir,

This has reference to your letter outdoor diary No. 488 dated 11.04.2025 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 19.05.2025 in presence of Mrs. Arshi (In-charge) and observed that the shortcoming intimated vide letter no. F6/DFS/MS/School/2022/590 dated 21/09/2022 (copy enclosed) has not been complied yet.

In view of above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

Encl: As above.


4/6/25

(VIRENDRA SINGH)
Chief Fire Officer
Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

012
836

c 23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/2022/ 590

Dated: 21/09/2022

To

The Principal,
N.D.M.C. Primary Model School (Girls),
Turkman Gate – 1, Delhi- 06.

Sub: - Regarding issuance of “Fire Safety Certificate” from fire safety point of view in r/o
N.D.M.C. Primary Co-Ed School, Turkman Gate - 1, Delhi-06.

Sir,

This has reference to your letter no. nil dated 28.07.2022 on the subject cited above. In this connection it is to inform you that officer concerned of this department inspected the school/ premises on 01.09.2022 to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education. At the time of inspection Mrs. Nighat Izhar Khan (Principal), was present and it was observed that the school building is comprised of ground plus three upper floors and have been partially complied the shortcomings issued vide letter no. F.6/DFS/MS/School/2012/809 dated 06.03.2012 except following which still exists:-

1. One additional staircase of 1.5 mtr width is required in the building.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

o/c

8/13/9

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.