

214

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

No.F.6/DFS/MS/School/2025/SZ/ 784

Dated: 13/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C Primary School**, Galib Pur, New Delhi-110073, comprised of ground floor only, having total 05 rooms (Including class rooms and office etc.) owned/occupied by MCD, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/614 dated 30.06.2022. The school building was re- inspected by the officer concerned of this department on dated 05.06.2025 in the presence of Ms. Jyoti Shoeran (In-Charge) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises (**ground floor only**) is fit for occupancy class "**Educational Building**" with effect from 13/06/2025 for a period of **three years**, subject to compliance of the conditions printed as under.

Issued on 13/06/2025 at New Delhi by.

(Atul Garg)  
 Director  
 Delhi Fire Service

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.
2. The Principal, M.C Primary School, Galib Pur, New Delhi-110073.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : M.C Primary School, Galib Pur, New Delhi-110073.
2. Building comprised of : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/614 dated 30.06.2022
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 05.06.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Ms. Jyoti Shoeran (In-Charge)
10. Year of Construction : 1980
11. Applicant's letter No. : NGZ/GB/187/39/25 dated 28.05.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 30.06.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"><li>Road width</li><li>Gate width</li><li>Width of internal road</li></ul>	Accessible (06 m) Old case N/A	06 m 3.65 m N/A	M/R M/R, being old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"><li>Upper Floors</li></ul>	N/A	N/A	Ground floor only
	<ul style="list-style-type: none"><li>Basements</li></ul>	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"><li>Upper Floor</li></ul>	N/A	N/A	Ground floor only
	<ul style="list-style-type: none"><li>Basements</li></ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Pressurization</li></ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.0 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Sealing of electrical shafts</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Fire Rating of shaft door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Water Curtain</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Fire Dampers</li></ul>	N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"><li>Basement</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Upper floors</li></ul>	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"><li>Total numbers</li></ul>	06 no's ABC/CO <sub>2</sub> type ISI marked	Provided	M/R
	<ul style="list-style-type: none"><li>Types</li></ul>		Provided	M/R
	<ul style="list-style-type: none"><li>IS marking</li></ul>		ISI marked	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"><li>Total numbers on each floor</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Length of hose reel hose</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Nozzle diameter</li></ul>	N/A	N/A	N/A





N/13

7.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC was issued vide letter number F.6/DFS/MS/School/2022/SZ/614 dated 30.06.2022, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Signature of Inspecting Officer  
Name: - R.K. Yadav  
Designation: - ADO (JKP)

DO (SW)

DO

9/6/25

CSO / 11/6/25  
9/6/2025

Director

IT letter is put up for sign please

DIRECTOR

11/6/2025