

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2025/SZ/ 667

Dated: 19/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M.C.D. Co-ed Primary School located at Goyla Khurd, New Delhi-110071, comprised of two blocks namely Old block & New block. Each block is comprised of ground plus one upper floor only, owned/occupied by the MCD, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2018/SZ/266 dated 15.02.2018. The school building was re-inspected by the officer concerned of this department on dated 14.05.2025 in the presence of Sh. Yogesh Kumar Chauhan, and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus one upper floor**) is fit for occupancy class "**Educational**" w.e.f. 19/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 19/05/2025 at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.
2. The Principal, Govt. Boys Sr. Sec. School located at Paprawat, New Delhi-110043.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : MCD CO-ED Primary School, Goyla Khurd, New Delhi-110071.
2. Building Comprised of : having two blocks, namely Old & New Block, each block comprised of ground plus one upper floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal/New
5. Details of Previous NOC : F.6/DFS/MS/School/2018/SZ/266 dated 15.02.2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 14.05.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Yogesh Kumar Chauhan
10. Year of Construction : 2010 (Old Block) & 2014 (New Block)
11. Applicant's letter No. : Nil, dated 13.03.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 15.02.2018	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 mtrs 4.5 mtrs. N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	01 no. in O blk 02 no.'s in N Blk N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	150 cms/additional staircase of 75 cms if less than 150 cms N/A	150 cms in O blk & 165 & 133 cms in N blk N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	150 cms	Provided	M/R
	f. Door Size	100 cms	110 cms (double doors in N Blk) & 100 cms in O blk	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	N/A Required	N/A Natural Ventilation	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	08 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			




	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A N/A N/A	N/A N/A N/A	
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stoppage</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> <li>Terrace level               <ul style="list-style-type: none"> <li>Pump House Access</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Pipe to Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
15.	<b>Exit Signage</b>	N/A	N/A	N/A
16.	<b>Provision of Lift</b> (No Lift)			
	<ul style="list-style-type: none"> <li>Presence of Lift Shaft</li> <li>Presence of Lift lobby</li> <li>Control room In lift Car</li> <li>Fire alarm sounding Switch</li> <li>Lift doors</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

N/A

	Standby power supply	N/A	N/A	N/A
	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2018/SZ/266 dated 15.02.2018, renewal under rule 37, of the Delhi Fire Service Rules 2010 is recommended.

  
Signature of Inspecting Officer  
Name: - R.K. Yadav  
Designation: - ADO (JKP)

DO (South West)

  
15/5/25

  
16/5/2025

  
16/5/25