



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2025/656

Dated: 19/08/2025

To

The Principal,
 MCD CO-ED School No. 1,
 Tughlakabad Extn., New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in r/o MCD CO-ED School No. 1 located at Tughlakabad Extn., New Delhi (School ID No. 1958097).

Sir,

With reference to the letter bearing outdoor dairy no. 11762 dated 24.01.2025 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 04.08.2025 in the presence of Mr. Rajeev Kumar Jain (Principal) and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. Fire Extinguishers found non functional.
2. First aid hose reels found non functional.
3. Fire pumps found non functional.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,

(Signature)
 18/8/2025
(Virendra Singh)
 Chief Fire Officer

Copy to:-

1. The Dy. Director of Education, Education Department (MCD), Center Zone, Jal Vihar, Lajpat Nagar, New Delhi-110024.