



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2025/ 180

Dated: 20/02/2025

FIRE SAFETY CERTIFICATE

Certified that the MCD Nigam Pratibha Primary School – I & II (Girls & Boys) located at Joshi Colony Delhi – 110092, Building comprised of A - Block - Ground + 02 upper floors & B - Block - Ground + 01 upper floor owned/occupied by MCD Nigam Pratibha Primary School, was granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2022/110 dated 03/02/2022. The premises was inspected by the officers concerned of this department on 15/02/2025 in the presence of the Mrs. Seema Narula (Principal) and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class “B” ‘Educational Building’ with effect from 20/02/2025 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 20/02/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi - 110092.
2. The Principal, Municipal Corporation Primary School – I, (Girls) located at Joshi Colony Delhi- 110092.
3. The Principal, Municipal Corporation Primary School - II, (Boys) located at Joshi Colony Delhi-110092.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building MCD Nigam Pratibha Primary School
at Joshi Colony Delhi-110092
2. Type of occupancy:- Educational Group-B
A-Block- Gr. + 02 & B-Block- Gr. +01 Upper floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/NDZ/2022/110 dated
03/02/2022
5. Fire safety directives No.- F.16/Estate/CC/FireSafety/2011/3298to3398
dated 01/03/2011
6. Date of inspection:- 15/02/2025
7. Name of the inspecting officer:- Yashwant Singh Meena ADO (L.N)
8. Name & designation of officer
From the building side:- Mrs. Seema Narula (Principal)
9. Year of construction:- 1992
10. Applicant's letter No:- Diary No. 12188 dated 06/02/2025

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement As per circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	10 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	A-Block - 02 nos. B-Block - 02 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors A-Block- Gr. + 02 upper floors B-Block- Gr. + 01 upper floor	1.5 & 1.30 m each	A-Block - 01 nos. 1.05 to 1.25 m 01 nos. 1.25 to 1.35 m B-Block - 02 nos. 1.30 m each	MR
	2. Basement	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	01 nos.	MR
	E. Width of corridor	1.5 mtr.	1.8 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 nos.	01 nos.	MR

u

N/14

	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	MR
	a) Draw-off connection	N/A	N/A	MR
	b) Fire service inlet	N/A	N/A	MR
	c) Access to tank	N/A	N/A	MR
	d) Over head tank capacity	10,000 liters.	10,000 liters.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A

	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2022/110 dated 03/02/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

D.O/EAST

Dy. C.O. (NBZ)

C.F.O.

Director

Director

17/02/2025

18/02/25

18/02/2025

18/02/25

AD/LN

Sir. F.T Letter is setup for sign. Please

19/2/2025

19/02/25