

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/82

Dated: 31../..01../2025

To

The Principal,  
MCD Nigam Pratibha School No -1, (Boys)  
Dr. Ambedkar Nagar, Sector-1 (Tigri) New Delhi 110062

Sub: Regarding issuance of FSC in r/o MCD Nigam Pratibha School No -1, (Boys) Dr. Ambedkar Nagar, Sector-1 (Tigri) New Delhi 110062

Sir,

This has reference to your letter, received through Email dated 18/12/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.01.2025 in the presence of Mr. Rajendra Kumar (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel provided but found nonfunctional.
2. Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
3. The Exit signage's found removed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 354 dated 26/06/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Directorate of Education, MCD, Civic Centre, Minto Road, New Delhi-110002