



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5/25/10
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 481

Dated: 06/06/2025

To,

The Principal,
MCD Pratibha Vidyalaya,
Patparganj-II Shift, Delhi-110091.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Pratibha Vidyalaya located at Patparganj-II Shift, Delhi - 110091.

Sir,

This has a reference to your outdoor dairy no. 1859 dated 20/05/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 27/05/2025 in the presence of Mr. Umesh Kumar (Principal) and observed that school building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. One staircase of 1.20 meter provided against requirement of 02 nos. of 1.5 meter each.
2. Only three fire extinguishers provided in place of required six fire extinguishers.
3. Fire pump of capacity 225 LPM provided against the requirement of 450 LPM.
4. Overhead water storage tank of 5000 liters provides against the requirement of 10,000 liters.
5. Exit signs not provided.
6. Two doors in six class room not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,

[Signature]
5/6/25

VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, MCD Pratibha Vidyalaya, Patparganj-II Shift, Delhi-110091.