

C/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 159

Dated: 17/03/2025

To,

The Principal,
MCD Pratibha Girls School,
Sagar Pur West-1, New Delhi- 110046.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o MCD Pratibha Girls School (Id- 1757169) at Sagar Pur West-1, New Delhi- 110046.

Sir,

Please refer to your letter No. Nil, dated 24.02.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 10.03.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Manju Chandna (Principal) was present and it was observed that the school having two blocks, namely Block-A comprised of ground plus one upper floor only & Block-B comprised of ground plus two upper floors, and have following shortcomings: -

1. Hose reels found provided but not functional.
3. Terrace fire pump of 450 LPM found provided but not functional.
4. Overhead water storage tank of 10,000 ltrs. provided but found empty.
5. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.