



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/187

Dated: 03/04/2025

To,

The Principal,  
MCD Pratibha Vidyalaya,  
Dayalpur-II Ward-247, Pocket- F, Delhi-110090.

**Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Pratibha Vidyalaya, located at Dayalpur-II Ward-247, Pocket- F, Delhi-110090.**

Sir,

This has a reference to your letter diary no.14517 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/03/2025 in the presence of Manager and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel at provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Exit & floors Signage's found removed in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

D/C DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.