GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELH HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

र्गाजादी न अमृत महोत्सव

No.F6/DFS/MS/School/2025/NDZ/ 357

Dated: 07/05/2025

0/21

To,

The Principal, MCD Pratibha School, Trilokpuri-7 (First shift), Delhi-110091.

Subject: - Regarding issuance of FSC in r/o MCD Pratibha School located at Trilokpuri-7 (First shift), Delhi-110091.

Sir,

Please refer to your Outdoor Dairy No.728 dated 17/04/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 03/05/2025 and observed that the shortcomings issued by this department vide letter no. F6/DFS/MS/School/2021/22 dated 19/01/2022 (copy overleaf) have still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Enclosed: as above

Yours faithfully,

DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi - 110002.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/2021/22

Dated: 19 /01/2022

To

The Principal, EDMC Primary School, Block-7, Trilok Puri Delhi-91.

Sub: Regarding grant of FSC in r/o EDMC Primary School at Block-7, Trilok Puri Delhi-91.

Sir,

This has reference to your email dated 25/10/2021on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 04/01/2022 in the presence of Mr. Kuldeep (MCD) and observed that following shortcoming was observed:-

- 1. Hose reel provided but not functional.
- 2. Fire pump provided but not functional.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully

Copy to:-

The Director of Education, EDMC, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi-92.

Director Delhi Fire Service

ok.