



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/54

Dated: 23/01/2025

To

The Principal,  
MCD Primary Boys School,  
Bijwasan, New Delhi-110061

**Sub: Renewal of Fire Safety Certificate in r/o MCD Primary Boys School located at Bijwasan, New Delhi**

Sir,

This has reference to your letter dated 19/12/2024 received through outdoor diary No. 10575 dated 20/12/2024. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 13/01/2025 in your presence from fire safety point of view. During course of inspection, the shortcomings observed are as below.

1. Hose reel hose provided found non-functional/damaged.
2. Terrace fire pump was not on auto mode.
3. Exit signage found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings above under intimation to this department for further action. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, MCD, Civic Center, Minto Road, New Delhi-110002