

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/School/NDZ/2025/ 1158

Dated: 18 / 09 /2025

**FIRE SAFETY CERTIFICATE**

Certified that the MCD Primary Co-Ed School, Kucha Moatter Khan, Mori Gate, Delhi - 110006, comprised of ground floor only was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/NDZ/2021/972 dated 01.12.2021. The school building was re-inspected by the officer concerned of this department on 04.09.2025 in the presence of Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and the building is fit for occupancy of class (Group-B) "Educational Building" (ground floor only), with effect from .....18/09/2025...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....18/09/2025.....at New Delhi by

  
18/09/2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
o/c 824 16/9

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,  
MCD Primary Co-Ed School (ID. No. 2162075), Kucha Moatter Khan, Mori Gate, Delhi - 06.

**Conditions for the validity of fire safety certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

# INSPECTION REPORT

1	Name & address of the building	MCD Primary Co-Ed School, Kucha Moatter Khan, Mori Gate, Delhi - 110006.		
2	Building is comprised of	Ground floor only		
3	Type of Occupancy	Educational		
4	Type of Case	renewal		
5	Details of Previous FSC	F6/DFS/MS/School/NDZ/2021/972 dated 01.12.2021		
6	Fire Safety direction letter No	F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated. 01.03.11		
7	Date of Inspection	04.09.2025		
8	Name of the Inspecting Officers	ADO (SPM)		
9	Name of the designation of Officer from the building side	Principal		
10	Year of Construction	1964		
11	Applicant's letter No	Letter outdoor diary No. 3840 dated 17.07.2025		
S. No	Minimum Standards on fire safety requirements as per circular no. F.16/Estate/fire safety/2011/3298-3398 dated 01.03.2011	Requirement as per education circular	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	06 m	03 m (one length hose distance away from 06 m main road)	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	A. Number of Staircases			
	Upper Floor	NA	NA	NA
	Basement	NA	NA	NA
	B. Width of Staircases			
	Upper Floor	NA	NA	NA
	Basement	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	NA	NA	NA
	E. Width of Corridor	NA	NA	NA
	G. Door size	1.0 m	1.0 m	MR
3	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	Basement	NA	NA	NA
	Upper floor	NA	NA	NA



5.	<b>Fire Extinguisher</b>			
	Total numbers	02 nos.	02 nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	Required	Provided	MR
6	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	N.A	NA	NA
8	<b>MOEFA</b>	N.A	NA	NA
9	<b>Public address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump for basement	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage.</b>	NA	NA	NA
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
<b>17</b>	<b>Standby power supply</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area.</b>			
	Total area	NA	NA	NA
	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Shortcoming communicated vide letter no. F6/DFS/MS/School/NDZ/2025/132 dated 04.03.2025 has been rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/972 dated 01.12.2021 is **recommended to be renewed** under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval & signature please.

*Sumit Kumar*  
08/09/2025

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD) *[Signature]*  
08/09/25  
Dy. C.F.O. (N002) *[Signature]*  
C.F.O. *[Signature]*  
11/09/2025  
Principal Director *[Signature]*