

C/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/ 596

Dated: 14 /07/ 2025

To

The Principal,
M.C. D. Primary School,
3316, Gali Farhatullah,
Kucha Pandit, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M.C. D. Primary School located at 3316, Gali Farhatullah, Kucha Pandit, Delhi - 110006.

Sir,

This has reference to your letter outdoor diary No. 2230 dated 29.05.2025 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 05.07.2025 in the presence of Mrs. Anjum Begam (Principal) and found that the school building is comprised of ground plus one upper floor. During inspection following shortcomings were observed:

1. The school building is not accessible to fire engine as approach road width is less than 06 mtrs.
2. An additional fire escape staircase not less than 0.75 m wide is required.
3. One additional ABC type fire extinguisher is required for first floor.
4. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.