



C/36

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/108

Dated: 14/02/2025

To

The Principal,  
M.C.D Primary School, Block A  
Mahavir Enclave Part-II/III,  
New Delhi-110059

Sub: **Regarding Fire Safety Certificate in r/o M.C.D. Primary School, Block A, Mahavir Enclave Part II/III, New Delhi (School ID-1757163).**

Sir,

This has reference to your email dated 29/11/2024, on the subject mentioned above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 30/01/2025 in your presence from fire safety point of view. During the course of inspection, the following shortcomings are observed: -

1. Hose reel found non-functional.
2. Terrace pump found non-functional.
3. Exit signage's found removed at some locations.
4. Overhead water storage tank of 10,000 ltr for firefighting not provided.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.