

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELIII HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/School/WZ/2025/ 1295

Dated: 06/11/2025

FIRE SAFETY CERTIFICATE

Certified that the M. C. D. Primary School, Kirti Nagar, Ind, Area, New Delhi-110015, comprised of 02 blocks, Ground & Ground + 02 upper floors owned/ occupied by M.C. D. Primary School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 24.10.2025 in the presence of Mrs. Mamta Tyagi (Principal) and that the building/ premise is fit for occupancy Group B Educational with effect from 6111225 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 66 11 2025 at New Delhi by

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

or my

Copy to:

- 1. The Principal, M.C. D. Primary School, Kirti Nagar, Ind, Area, New Delhi-110015.
- 2. The Director, Education, North MCD, Civic Center, New Delhi.

Conditions for validity of Fire Safety Certificate;

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

			INSPE	ECTION REPORT	,			
1	. Name & a	ddress of the building	MC	D Primary School	ol, Kirti Nagar, Ind, A	Area, New Delh		
			11001	5.	n, Killi Hagai, inch			
_	. Type of O		Educational Renewal (02 Blocks, Ground & Ground + Two Upper Floors)			V Floors)		
	. Type of Ca							
		Previous NOC	-NA-	NA-				
		directives letter No		OOE Circular 262-362 dated 17.01.2005 4.10.2025 h. Ajay Kumar Sharma ADO (WP/MN) frs. Mamta Tyagi (Principal)				
	Date of ins	Chicago and Chicag	24.10.					
-		specting Officer						
0		designation of officers uilding side	IVIIS, IV	riainta Tyagi (Time.	F,			
9	. Year of Co		1999					
1	0. Applicant's	letter No.	Outdoo	or Diary No- 6140 c	lated- 18.09.2025	Remarks		
S.	Minimum	Standards on fire preve		DOE Cir. 262-362	Provided at site	MR/NMR		
No		fety U/R 33		dated 17.01.2025				
1.	Access to I				Provided	MR		
	• Roa	d width		Accessible	Provided	MR		
	• Gat	e width		Accessible	-NA-	-NA-		
	• Wic	ith of internal road		-NA-	-NA-			
2.		Vidth, Type & Arrangen	nent of	Exits				
	a. Number	of staircases			02nos.	MR		
	COLL COLL COLL COLL COLL COLL COLL COLL	Ipper Floors		02nos.	-NA-	-NA-		
91		asements		-NA-	-NA-			
		Ith of staircases				T		
		10.5		If one staircase is less then 1.5m then alternate staircase is	1.20m & 1.5m	MR		
		pper Floor		not less than 0.75m	-NA-	-NA-		
	Basements			-NANA-				
	c. Protection of exits			-NA-	-NA-	-NA-		
		re check door		-NA-	-NA-	-NA-		
	•	Pressurization		01nos.	01nos.	-NA-		
	d. No. of co	continuous staircases to terrace		-NA-	-NA-	-NA-		
	e. Width of	Corridor		lm	Provided	- MR		
	f. Door Size			1111	1.0			
3.	Compartme	entation		-NA-	-NA-	-NA-		
	a) Fire check door			-NA-	-NA-	-NA-		
	b) Seali	ng of electrical shafts			-NA-	-NA-		
	c) Fire Rating of shaft door			-NA-	-NA-	-NA-		
	d) Wate	r Curtain			-NA-	-NA-		
ŀ	e) Fire Dampers		-NA-	4.34.4	15.00			
4.	Smoke Management System			-NA-	-NA-	-NA-		
	a) Baser			Required	Natural ventilation	MR		
	b) Upper			Required	1 satural semination			
5.	Fire Extinguishers			00 non	Provided	MR		
	a) Total numbers			08 nos. ABC/CO2	ABC/CO2	MR		
	b) Types			ISI marked	Provided	MR		
f	c) IS marking			151 marked	1 TOVIDED			
, 1	First-Aid Hose Reels			Olnos.	Provided	M&		
	a) Total numbers on each floor			30mm	Provided	MR.		
-	b) Length	of hose reel hose		JUHH	riovided	IVI N		

M

				140		
	c) Negal V	5m	Provided	MR		
7.	c) Nozzle diameter					
	Automatic fire detection and alarming syst a) Type of detectors	em	-NA-	-NA-		
	b) Location Co.	-NA-	-NA-	-NA-		
1	b) Location of Main Panel c) Location of B	-NA-	-NA-	-NA-		
	c) Location of Repeater Panel d) Alternate source of power	-NA-	-NA-	-NA-		
	1100fere' I '	-NA-	-NA	-NA-		
8.	LICETA	-NA-		-NA-		
9.	Public Address System	-NA-	-NA-	-NA-		
10.	Tatomatic Sprinkles C.	-NA-	-NA-			
	, Suscinent			-NA-		
	b) Ground & Lines El	-NA-	-NA-			
11.		-NA-	-NA-	-NA-		
-	Internal Hydrants	-NA-	-NA-	-NA-		
	a) Size of riser/d					
	- turillet of had	-NA-	-NA-	-NA-		
2.	c) Hose Box	-NA-	-NA-	-NA-		
	Yard Hydrants	-NA-	-NA-	-NA-		
	a) Total number of					
3.	b) Hose Box	-NA-	-NA-	-NA-		
	Pumping Arrangements	-NA-	-NA	-NA-		
	Olound Level	27.				
	Discharge of main Pump Head of Mai	-NA-	-NA-	-NA-		
		-NA-	-NA-	-NA-		
	i uniper of main	-NA-	-NA-	-NA-		
	TOURCY Pilmn and	-NA-	-NA-	-NA-		
	Jockey pump head	-NA-	-NA-	-NA-		
	Standby Pump out put Standby Pump Head	-NA-	-NA-	-NA-		
	Auto Starting A	-NA-	-NA-	-NA-		
	Auto Starting/Manual Stopping Pump House Access	-NA-	-NA-	-NA-		
	Terrace level	-NA-	-NA-	-NA-		
			-NA-	-NA-		
	Discharge of pump					
	Head of the pump	450 lpm 40 m	Provided	MR		
	Power Supply	Required	Provided	MR		
1.	Auto Starting of pump	Required	Provided	MR		
-	Captive Water Storage for fire fighting	- dunica	Provided	MR		
	Underground tank capacity					
	> Draw-off connection	- 1/253 h	-NA-	-NA-		
	Fire service inlet	-NA-	-NA-	-NA-		
	> Access to tank	-NA-	Provided	-NA-		
		-NA-	-NA-			
	Overhead Tank capacity	10,000 ltrs	Provided	-NA-		
i.	Exit Signage.	Required	Provided	MR		
i.	Provision of Lifts.	MR				
	a) Pressurization of Lift Shaft	-NA-	-NA			
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-		
		-NA-	-NA-	-NA-		
		-NA-		-NA-		
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-		
	e) Lift Signage	-IN/A-	-NA-	-NA-		

2							
D	Standby power supply	-NA-	-NA-	-NA-			
18.	posige Area.						
	a) Total Area	-NA-	-NA-	-NA-			
	b) Location	-NA-	-NA-	-NA-			
9.	Fire Control Room						
	a) Detector System Panel	-NA-	-NA-	-NA-			
	b) Flow Switch Panel	-NA-	-NA-	-NA-			
	c) PA System Panel	-NA-	-NA-	-NA-			
	d) Battery backup	-NA-	-NA-	-NA-			
	e) Building Floor Plans	-NA-	-NA-	-NA-			
0.	Special Fire Protection System for Protection of special Risks, if any:	Required 02 ABC type extinguishers near elect. Panel	Provided	MR			

Accordingly, the fire protection systems provided in the building were tested/ checked

randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 451 & 297 dated 19.07.2025 & 28.05.2024, under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

1 28/10/nc

Signature of the Inspecting Officer Name Ajay Kumar Sharma Designation ADO(WP/MN)

DO ON MAK

Principal Director

by. Cfo

F.T. please.

ADO(MN)

For letter is port up to kind peused & Sign. Pears.

Derofur

21/25

F.P. wing