

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/732

Dated: 17/9/2025

To,  
The Principal,  
MCD Primary School,  
Madhu Vihar, New Delhi- 110059.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o MCD Primary School at Madhu Vihar, Uttam Nagar, New Delhi- 110059.**

Sir,

Please refer to your letter No. Nil, dated 16.07.2025, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the school building on dated 01.09.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Seema Sharma (Principal) was present and it was observed that the school building having two blocks, namely New Block & Old Block (each block are comprised of ground plus two upper floors), and have following shortcomings:-

1. Hose reels found provided in each block but found not functional
2. Terrace fire pump of 450 LPM provided in each block but found not functional.
3. Exit signage's are found removed at some places.
4. Old block comprised of ground plus two upper floors found in unsafe condition. You are requested to submit building stability certificate of Old Block.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

  
16/9/2025  
(Virendra Singh)  
Chief Fire Officer

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. Director of Education, MCD, Civic Centre N. Delhi.