



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

0108

75  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2025/ 329

Dated: 05/05/2025

To

The Principal,  
MCD (CO-ED) Primary School,  
Nangli Razapur, New Delhi-13.

Sub:- Regarding renewal of Fire Safety Certificate in r/o MCD (CO-ED) Primary School, located at Nangli Razapur, New Delhi-13 (School ID No. 2162020).

Sir,

With reference to the letter bearing outdoor dairy no. 14245 dated 10.03.2025 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 09.04.2025 in the presence of Mr. Satwant (HOS) and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. First aid hose reels has not been provided.
2. Fire pump of 450 LPM with head 40 m has not been provided.
3. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
4. Exit signage has not been provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)

Director

Delhi Fire Service

o/c

Copy to:-

1. The Dy. Director of Education, Education Department (MCD), Center Zone, Jal Vihar, Lajpat Nagar, New Delhi-110024.