

C24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**


No.F.6/DFS/MS/School/2025/SZ/ 1217

Dated: 03/10/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M.C.D. Primary School located at Surakhpur, Najafgarh Zone, New Delhi-110072, comprised of ground floor only, owned/occupied by M.C.D, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/552 dated 20.05.2022. The school building was re-inspected by the officer concerned of this department on dated 23.09.2025 in the presence of Sh. Surender Kumar (Principal), and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (ground floor only) is fit for occupancy class "Educational Building" w.e.f. 03/10/2025 for a period of th ree years, subject to compliance of the conditions printed as under.

Issued on 03/10/2025 at New Delhi by.

  
 (A. K. Malik)  
 Dy. Chief Fire Officer  
 South Zone  
 9/10/25

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.
2. The Principal, M.C.D. Primary School at Surakhpur, Najafgarh Zone, New Delhi-110072.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/IS

**INSPECTION REPORT**

1. Name & address of the building : M.C.D. Primary School, Surakhpur, Najafgarh Zone, New Delhi-72
2. Building comprised of : ground floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/552 dated 20.05.2022
6. Fire Safety directives letter No : Circular No. 3298 to 3398 dated 01.03.2011
7. Date of inspection : 23.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Surender Kumar (Principal)
10. Year of Construction : Before 2015
11. Applicant's letter No. : Nil dated Nil, Outdoor dairy No. 5590 dated 03.09.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"><li>Road width</li><li>Gate width</li><li>Width of internal road</li></ul>	Accessible 06 mtrs 4.5 mtrs N/A	Provided 04 mtrs. N/A	MR MR, old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	School running at GF only		
	<ul style="list-style-type: none"><li>Upper Floors</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Basements</li></ul>	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"><li>Upper Floor</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Basements</li></ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Pressurization</li></ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Class Room Door Size	1.0 m	1.05m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"><li>Fire check door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Sealing of electrical shafts</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Fire Rating of shaft door</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Water Curtain</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Fire Dampers</li></ul>	N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"><li>Basements</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Upper floors</li></ul>	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"><li>Total numbers</li></ul>	03 No's ABC/CO <sub>2</sub> type ISI marked	Provided	MR
	<ul style="list-style-type: none"><li>Types</li></ul>		Provided	MR
	<ul style="list-style-type: none"><li>IS marking</li></ul>		ISI marked	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"><li>Total numbers on each floor</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Length of hose reel hose</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Nozzle diameter</li></ul>	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			

PS



N/A

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			

N/12

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2022/SZ/552 dated 20.05.2022, is recommended to be renewed in accordance with the Circular No. 3298 to 3398 dated 01.03.2011 issued by the Director of Education.

Signature of Inspecting Officer  
Name- R.K Yadav  
Designation- ADO (JKP)

DO (SW) R.K  
29/9/25

CFO Wing  
26/9/2025

Principal Director

Cfo to Jem.

26/09/25

CFO W

ADO (JKP)

F-T letter is put up for sign. No.

R.K  
01/10/2025

DY CFO (S2)

A.K. MALIK  
11/10/25

M.S. cell