



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11/25
आजादी का
अमृत महोत्सव
C-31

No. F6 /DFS/MS/School/SZ/2025/ 838

Dated: 27/ 11 /2025

To,

The Principal,
MCD Primary School
Tajpur Pahari -1, New Delhi - 110044.

Sub: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Tajpur Pahari-I, New Delhi - 110044.

Sir,

This has a reference to your Outdoor Diary no. 5556 dated 02.09.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/11/2025 in the presence of Mrs. Kanta Kumari Dagar (Principal) and observed that building comprised of ground plus three upper floors and following shortcomings were observed during time of inspection:

1. Hose reel hose provided but nonfunctional.
2. Fire pump of 450 LPM provided but nonfunctional.
3. Overhead tank capacity 10,000 liters found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A.K.Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c @

Copy to: -

1. Director of Education, South MCD, Civic Centre, Minto Road Delhi – 110002.
2. The Principal, MCD Primary School located at Tajpur Pahari -1 New Delhi-110044.