



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE **NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/ 341

Dated 06 05 2025

To,

The Principal, M. C.Primary School East Old Seelampur, Delhi-110031.

Sub: - Regarding Issuanceof Fire Safety Certificate r/o MCD Primary School at East Old Seelampur, Delhi-110031.

Sir,

With reference to your Outdoor Diary No. 14626 dated 18/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 23/04/2025 of the above mentioned School from fire safety point of view in presence of the Mr. Pritam Das, In-charge. The building comprised of ground plus two upper floors only. Following shortcomings were observed during the time of inspection.

- 1. An additional staircase of width 0.75 meter not provided.
- 2. First Aid Hose reels provided but not functional.
- 3. Fire pump having 220 lpm head 40 meters head provided but not functional.

4. Exit signs are not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faith

Copy to:-

The Dy. Director of Education, MCD Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi- 110092