



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

C/2



No.F.6/DFS/MS/School/2025/NDZ/ 501

Dated: 09/06/2025

To,

The Principal,
M C D Primary School
G- Block, Jagat Puri, Delhi-110051.
Delhi-110051

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M C D Primary School located at
G- Block, Jagat Puri, Delhi-110051.**

Sir,

This is in reference to your letter no. nil dated 09/04/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the school on dated 20/05/2025 in presence of In-charge and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/2015/1589 dated 17/07/2015 (copy enclosed) have not been complied yet.

In view of the above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours faithfully

[Signature]
6/6/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER

Encl. As above

Copy to:-

The Director of Education (MCD)
15th Floor, E-Block, Dr. S.P. Mukahrjee Civic Center, JLN Marg, New Delhi-110002

C/25 E/16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. 66/DFS/MS/School/2015/1588
To,

Dated: 17/07/15

The Principal (2nd Shift)
EDMC Primary School,
Jagatpuri, G -Block, Delhi-51

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, Jagatpuri, G -Block, Delhi-51


Madam,

Please refer to your letter dated 05.06.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. The School is not accessible to fire engines as approach road width is less than 6 meters.
2. An additional staircase is required.
3. First Aid Hose reels not provided.
4. Fire pump having capacity 450 LPM out put at 40 m head not provided.
5. Over head water storage tank 10,000 liters capacity for firefighting not provided.
6. Exit signs not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under intimation to this department for further course of action.

Yours faithfully


(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

Copy to:-

- 1 The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (1st Shift)
EDMC Primary School, Jagatpuri, G -Block, Delhi-51