

C/28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 541

Dated: 23 06 /2025

To

The Principal,
M.C.D. Primary School,
Kapashera No. 2/1
New Delhi-110037

Sub: Renewal of Fire Safety Certificate in r/o M.C.D. Primary School, Kapashera No. 2/1, New Delhi-110037 (School ID: 1757232)

Madam,

Please refer to your letter No. Nil dated 20/05/2025 received in this department vide outdoor diary No. 2057 dated 26/05/2025. In this connection, it is to inform you that the school premise was inspected by the officer concerned of this department on 16/06/2025 in your presence from fire safety point of view. During the course of inspection, the shortcomings observed are as below: -

1. Hose reel found non-functional.
2. Terrace pump found non-functional.
3. Overhead water storage tank for fire-fighting found empty.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings mentioned above, under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Municipal Corporation of Delhi, 9th Floor, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002