

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI-HEADQUARTERS: DELIII FIRE SERVICE: NEW DELHI- 110001

आज़ादी वा अगृत महोत्सव

No. F6/DFS/MS/School/2025/NDZ/ 510

Dated: 10 / 06 /2025

To,

The Principal, MCD Primary School, A-3, Mayur Vihar Phase-III, Delhi- 110096.

Sub.: - Reg. Fire Safety Certificate in r/o MCD Primary School, located at A-3, Mayur Vihar Phase-III, Delhi- 110096.

Sir,

Please refer to your email dated 19.05.2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 22/05/2025 in the presence of Principal and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/School/2021/129 dated 04/03/2021 (copy enclosed).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: as above

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
OC DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, MCD, J.L.N. Marg, Civic Centre, New Delhi-110002.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/129

Dated: 04 /03/2021

To

The Principal, EDMC Primary School, A-3, Mayur Vihar, Ph-III, Delhi-96.

Sub: Regarding Renewal of FSC in r/o EDMC Primary School located at A-3, Mayur Vihar, Ph-III, Delhi-96.

Sir,

This has reference to email dated 08/02/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 01/03/2021 in the presence of Mr. A.S. Sharma (Principal) and the following shortcomings were observed:-

 Earlier block was G + 01 upper floor, now one more floor added, hence building is G + 02 upper floors and no fire fighting system is provided as per NBC.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Delhi Fire Service

2/4

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.