



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/13



No. F6/DFS/MS/WZ/2025/ 571

Dated: 03/07/2025

To,

The Principal,
MCD Primary Co-ed School,
B-2, Ashok Vihar, Phase-2,
Delhi-110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MCD Primary Co-ed School located at B-2, Ashok Vihar, Phase-2, Delhi- 110052.

Sir,

This has reference to your e mail id dated 17/04/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.06.2025 to see the to see the compliance of shortcomings issued vide letter no. F6/DFS/MS/School/2015/1793 dated 06/08/2015. Smt. Yogita Thukral (Principal) was present at the time of inspection. During the course of inspection it was observed that previously the school building was comprised of 04 Blocks (02 Blocks of G+1 & 02 Blocks of Ground floor only) but now the school building is comprised of 02 Blocks (Ground and First floor).

The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	Width of class room varies from 80 cm to 108 cm against required 100 cm clear width and class room having more than 45 students required two doors of 100 cm.	Rectified
2.	Width of staircase in Block -2 is less than 1.5 m it should be extended to 1.5 m or one additional staircase of 0.75 m to be provided.	Not Rectified
3.	Only four extinguishers of ABC type of 5 kg capacity are provided against required 10 fire extinguishers.	Rectified as required 5 extinguishers provided for two blocks.

In addition to the above mentioned shortcoming it is to inform you that the gate width found 3 m against the required width of 4.5 m & electrical panel and electric meter installed under the staircase have to be removed to a safer place or been segregated.

In view of the above shortcomings, the request for issuance of Fire Safety Certificate can't be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this regard.

Yours faithfully,

(Atul Garg)
Director

Ph. 011-23414000

01/07/2025

Copy to:-

1. The Director of Education, MCD, Civic Centre, New Delhi.