

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2025 /School/WZ/ 522

Dated

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary School located at BK-2, Shalimar Bagh, Delhi-110088 comprised of Ground and First floor was issued FSC by this department vide letter No F6 /DFS/MS/School/WZ/2022/304 dated 23.03.2022. The premise was re-inspected by the officer concerned of this department on 08.04.2025 in the presence of Smt. Pooja (In-charge), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from .. 22.04. 2025. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ... 22 104 2025 at New Delhi by

Copy to:-

1. The Director, Education, MCD, Civic Centre, Delhi.

2. The Principal, M.C.D. Primary School located at BK-2, Shalimar Bagh, Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.

2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

5. This certificate cannot be treated in any case for regularizations of unauthorized

6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

8. All the means of escape shall be kept free of any obstruction all the time to evacuate the

occupant, in a safe manner, in the event of emergency.

9. Electric Panel and electric meter under the staircase must be removed to a safer place or been segregated within a period of three months from the date of issuance of the Fire Safety Certificate. Failing to do so the Fire Safety Certificate will be null and **INSPECTION REPORT**

Name & address of the building :

M.C.D Primary School, BK-2, Shalimar Bagh, Delhi- 110088.

Type of Occupancy 2.

Educational

Ground plus First floor

Renewal

Building Comprised of
 Type of Case
 Details of Previous NOC

F6/DFS/MS/School/WZ/2022/304 dated 23/03/2022 DOE circular No. 3298-3398 dated 01/03/2011

6. Fire Safety directives letter No : 7. Date of inspection

08/04/2025

R.K.Sinha, ADO (BW)

8. Name of Inspecting Officer9. Name and designation of officers

From the building side

Smt. Pooja (In-charge)

10. Year of Construction

2011

S.	11. Applicant's letter No. : Minimum Standards on fire	E Mail ID Dated 18/0. DOE	Provided at site	Remarks		
No.	prevention and fire safety U/R 33	Requirement	ACT CON GREEN	MR/NMR		
1.	Access to building					
	Road width	6 m	Provided	MR		
	Gate width	4.5 m	3.5 m	MR(old case)		
	 Width of internal road 	NA	NA	NA		
2.	Number, Width, Type & Arrangement of Exits					
	a. Number of staircases					
	Upper Floors	02	02	MR		
	Basements	NA	NA	NA		
	b. Width of staircases	Ti and the state of the state o				
	Upper Floor	1.50 m or less & 0.75 m	1.40 m & 1.32 m	MR		
	Basements	NA	NA	NA		
	c. Protection of exits			L		
	Fire check door	NA	NA	NA		
	Pressurization	NA	NA	NA		
	d. No. of continuous staircases to terrace	NA	NA	NA		
	e. Width of Corridor	1.5 m	Provided	MR		
	f. Door Size	l m	Provided	MR		
3.	Compartmentation					
	Fire check door	NA	NA	NA		
		NA NA	NA	NA		
	Sealing of electrical shafts	NA NA	NA NA	NA		
	Fire Rating of shaft door	NA NA	NA NA	NA NA		
	Water Curtain Fig. Downers	NA NA	NA NA	NA NA		
1	Fire Dampers Smoke Management System	NA.	· IM	1,12		
4.		NIA I	NA	NA		
	Basements	NA .	TOTAL PARTY	NT-0002		
	Upper floors	Required	Naturally Ventilated	MR		
5.	Fire Extinguishers					
	Total numbers	08	Provided	MR		
	Types	ABC Type	Provided	MR		
	IS marking	Required	Provided	MR		
6,	First-Aid Hose Reels	755		24.1		
	Total numbers on each floor	NA	NA NA	NA NA		
	 Length of hose reel hose 	NA	NA	NA		
	Nozzle diameter	NA	NA	NA		
7.	Automatic fire detection and alarming system					
	Type of detectors	NA	NA	NA		
	 Location of Main Panel 	NA	NA	NA		
	Location of Repeater Panel	NA	NA	NA		
	Alternate source of power	NA	NA	NA		
	Hooters' Location	NA	NA	NA		
		â/				

9. Pu 10. Au 11. In 12. Ya 13. Pu	DEFA ublic Address System Basement Ground Floor Sprinkler above false ceiling atternal Hydrants Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level Discharge of main Pump	NA	NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA	
10. Au	Basement Ground Floor Sprinkler above false ceiling atternal Hydrants Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA	
11. In 12. Yi	Basement Ground Floor Sprinkler above false ceiling aternal Hydrants Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box amping Arrangements Ground Level	NA NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA	
12. Ys	Ground Floor Sprinkler above false ceiling Iternal Hydrants Size of riser/down-comer Number of hydrants per floor Hose Box I ard Hydrants Total number of hydrants Hose Box I mping Arrangements Ground Level	NA NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA	
12. Ys	Sprinkler above false ceiling Iternal Hydrants Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA NA NA NA NA	NA NA NA NA NA	NA NA NA	
12. Ys	Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA NA NA	NA NA NA	NA NA	
12. Ys	Size of riser/down-comer Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA	NA NA	NA	
13. Pu	Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA	NA NA	NA	
13. Pu	Number of hydrants per floor Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA	NA NA	NA	
13. Pu	Hose Box ard Hydrants Total number of hydrants Hose Box umping Arrangements Ground Level	NA NA	NA		
13. Pu	Total number of hydrants Hose Box umping Arrangements Ground Level	NA			
	Hose Box umping Arrangements Ground Level	25072817	N/A		
	Hose Box umping Arrangements Ground Level	25072817	N.A.	NA NA	
	Ground Level	IVA	NA NA	NA NA	
	Ground Level		IVA	1,11	
14. Ca					
14. Ca	Discharge of main Pump				
14. Ca		NA NA	NA NA	NA NA	
14. Ca	Head of Main pump	NA	NA		
14. Ca	Number of main pumps	NA	NA	NA	
14. Ca	Jockey Pump out put	NA	NA	NA	
14. Ca	Jockey pump head	NA	NA	. NA	
14. Ca	Standby Pump out put	NA	NA	NA NA	
14. Ca	Standby Pump Head	NA	NA	NA NA	
14. Ca	Auto Starting/Manual Stopping	NA	NA	NA	
14. Ca	> Pump House Access	NA	NA	NA	
14. Ca	Terrace level	,			
14. Ca		NA	NA	NA	
14. Ca	Discharge of pump	NA NA	NA	NA	
14. Ca	Head of the pump		4927900-027		
14. Ca	➤ Power Supply	NA	NA	NA NA	
14. Ca	➤ Auto Starting of pump	NA	NA	NA	
	aptive Water Storage for fire fighting			NA NA	
	 Underground tank capacity 	NA	NA	NA NA	
	> Draw-off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA NA	NA NA	
	> Access to tank	NA	NA	1	
	Overhead Tank capacity	NA -	NA Provided	NA MR	
15. Ex	xit Signage.	Required	Provided	MIK	
16. Pr	ovision of Lifts.				
	Pressurization of Lift Shaft	NA	NA	NA NA	
-	n : .:CI iA lobby	NA	NA	NA	
-	Cor	NA	NA	NA NA	
		NA	NA	NA	
	Fireman's Grounding Switch	NA	NA	NA	
	Lift Signage	NA NA	NA	NA	
17. Sta	andby power supply	1321	the set		
18. Re	Refuge Area.				
		NA	NA	NA NA	
	> Total Area	NA	NA	NA NA	

n/

4	/				
3	• Det	ctor System Panel	NA	NA	NA
1	• Flo	v Switch Panel	NA	NA	NA NA
/	• PA	System Panel	NA	NA	NA NA
	Bat	ery backup	NA	NA	NA
	• Bui	ding Floor Plans	NA	NA	NA
0.	Special Fire Protection	Protection System for of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel found installed under the staircase which have to be removed to a safer place or been segregated.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/WZ/2022/304 dated 23/03/2022.

Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

DCFO/ 1386-NR Dateu. 15/0.4/25... 13ty /2025

15 unson

of the who

, sign N

16/4/2

MA

Director