

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI <u>HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001</u>



No F 6/DFS/MS/2025/School/WZ/1017

Dated 19 08 2025

## **FIRE SAFETY CERTIFICATE**

Issued on 19 08 2025 at New Delhi by

(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Director, Education, MCD, Civic Centre, Delhi.

2. The Principal, MC Primary Co-ed School located at Garhi Randhala, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

5. This certificate cannot be treated in any case for regularizations of unauthorized construction.

6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <a href="www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>

8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

	1							
	Name &	ddress of the building :	N	15				
	3. Pype of	ddress of the barre	INSPECTION REPO	DT				
	4. Tuilding	ccupancy building :	MCD Primary Co-ed Sc	hool located at Carl: Dan Ja	-I- D-II-: 110081			
l	7 7 010	rised of Educational						
	6. Fire cof	Previous	Ground plus first floor					
	Date of	Comprised of Educational Ground plus first floor  F Previous NOC Renewal  This pection Inspection Officer designation of exemple 1. Six and the second located at Garhi Randhala, Delhi- 110081.  Educational Ground plus first floor  Renewal F6/DFS/MS/2022/School/WZ/392 dated 06/04/2022  DOE circular No. 3298-3398 dated 01/03/2011  31/07/2025  R.K.Sinha, ADO (RW)						
	Name and	Ispecting Office :	31/07/2025	3-3398 dated 01/03/2011				
		Inspecting Officer and designation of officers building side Construction is construction.  DOE circular No. 3298-3398 dated 01/03/2011  31/07/2025  R.K.Sinha, ADO (BW)						
	10. Year of Co	nstruction side						
S.	11. Applicant'	s letter N	Ms.Meenu (In-charge)					
No.	prever u	tandard.						
1.	Access	s letter No.  Standards on fire and fire safety U/R 33	Outdoor Diary No. 180	08 dated 03/07/2025				
	23 10 PI	vila: Safety [ /R 32	Requirement	Provided at site	Remarks			
	100	Wide	- quirement		MR/NMR			
2.	Jac	width	6 m	Provided				
۷.	Number Wil	th of internal road idth, Type & Arrangem	4.5 m	Directly Accessible	MR			
		7 Type V. A	NA	NA NA	MR			
	a. Number of	fat	ent of Exits	TVA	NA			
		per Floors						
	b. Width . c	ements	01	02	MD			
	b. Width of	staircases	NA	NA	MR			
	Up	er Floor			NA			
	- Kac		1.50 m	1.56 m & 1.77 m				
	rotection	of exite	NA	NA NA	MR			
	Fire	check door		IVA	NA			
	Pre	Surization	NA	MA	3			
	d. No. of co	ontinuous staircases to	NA	NA NA	NA			
	terrace	nunuous staircases to		NA	NA			
			NA	NA				
	e. Width of	Corridor .	N	INA	NA			
	f. Door Siz	e	NA	NA	NIA			
3.	Compartme	ntation	1 m	Provided	NA			
	• Fine	1 1 1	1		MR			
		check door	NA					
	• Seali	ng of electrical shafts	NA	NA	NA			
	rire	Rating of shaft door		NA	NA			
	• Wate	Curtain	NA NA	NA				
	• Fire	Dampers	NA NA	NA	NA			
1.	Smoke Man	agement System	INA	NA	NA			
		ments			NA			
		er floors	NA	NA				
	- Орре	110013	Required	Naturally Ventilated	NA			
5.	Fire Futing	lah aya		venillated	MR			
,.	Fire Extingu	numbers						
		The state of the s	04 Nos.	Provided				
	<ul> <li>Type</li> </ul>		ABC/ CO2 Type	Provided	MR			
		arking	Required	Provided	MR			
5.	First-Aid Ho			rovided	MR			
		numbers on each floor	NA	NA				
		th of hose reel hose	NA	NA	NA			
	Nozz	le diameter	NA	NA	NA			
			ung a		NA			
- 1	Automatic fi	re detection and alarmi	ng system					
.	Т	of detectors	NA	NA				
	• Type	(A)	NA	NA	NA			
•	• Locat	ion of Main Panel						
•	• Locat	ion of Main Panel ion of Repeater Panel	NA		NA			
7.	• Locat	ion of Repeater Panel		NA	NA NA			
7.	Locat     Locat     Altern	ion of Main Panel ion of Repeater Panel nate source of power ers' Location	NA					

8.	MOEFA	10/16	N 16					
9.	Public Address System	NA	NA					
10.		NA	NA NA	N N				
10.	Automatic Sprinkler System			, N				
	Basement							
	Ground Floor	NA	NA	N/				
		NA	NA	N.				
11.	• Sprinkler above false ceiling Internal Hydrants	NA	NA	N.				
	• Size of riser/down							
	Number of hydrants per floor	NA	NA	N/				
	Hose Box	NA NA	NA	N/A				
12.	Yard Hydrants	INA NA	NA	NA				
	Total number of hydrants	NA						
	Hose Box	NA NA	NA NA	NA				
13.	Pumping Arrangements	IMA	NA	NA				
	Ground Level							
	Discharge of main Pump	NA	NIA					
	➢ Head of Main pump	NA NA	NA NA	NA NA				
	Number of main pumps	NA	NA					
	Jockey Pump out put	NA .	NA NA	NA NA				
	Jockey pump head	NA	NA NA	NA NA				
1	➤ Standby Pump out put	NA	NA NA	NA NA				
-	> Standby Pump Head	NA	NA	NA NA				
	➤ Auto Starting/Manual Stopping	NA	NA	NA NA				
	➤ Pump House Access	NA	NA	NA .				
	Terrace level	50 to						
H	➢ Discharge of pump	NIA I	27.					
		NA NA	NA NA	NA NA				
	➤ Head of the pump	#/26.60	. NA	NA				
	> Power Supply	NA	NA	NA				
	Auto Starting of pump	NA	NA	NA				
. (	Captive Water Storage for fire fighting							
	Underground tank capacity	NA	NA	NA				
	> Draw-off connection	NA	NA	NA				
L	> Fire service inlet	NA NA	NA	. NA				
	> Access to tank	NA	NA	NA				
E	Overhead Tank capacity  Exit Signage.	NA NA	NA NA	NA NA				
	rovision of Lifts.							
r	New Control of the Co							
St	Pressurization of Lift Shaft	NA NA	NA NA	NA NA				
	Pressurization of Lift lobby	NA NA	NA NA	NA NA				
	Communication In lift Car	NA NA	NA NA	NA				
	Fireman's Grounding Switch	NA NA	NA NA	NA				
	Lift Signage	NA NA	NA NA	NA				
St	andby power supply	1MA	\$150/EX					
Re	efuge Area.							
+	> Total Area	NA	NA	NA NA				
	> Location	NA	NA	NA				

Detector System Panel	NA	NA	NA
Now Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/392 dated 06/04/2022.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.