



No. F6/DFS/MS/School/NDZ/2025/ 528

Dated: 7/06/2025

To,

The Principal,  
MCD Pratibha Vidyalaya  
Gharoli Village - II,  
Delhi-110096.

**Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Pratibha Vidyalaya located at Gharoli Village - II, Delhi - 110096.**

Sir,


This has a reference to your Outdoor Dairy No. 1701 dated 15/05/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 03/06/2025 in the presence of Mr. Ravi Kanta (Principal) and observed that school building comprised of ground plus two upper floors.

**Following shortcomings were observed during time of inspection:**

1. One staircase of 1.50 meters provided against requirement of 02 nos. of 1.50 meter each.
2. Fire pump of capacity 450 LPM not provided.
3. Overhead water storage tank of 10,000 liters not provided.
4. Exit signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,

  
12/6/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, MCD, Plot No. 419, Udyog Sadan, FIE, Patparganj, Delhi - 110092.
2. The Principal, MCD Pratibha Vidyalaya located at Gharoli Village - II, Delhi - 110096.