

0119

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/School/2025/NDZ/ 480

Dated: 06/06/2025

To

The Principal
M.C.D. Primary School,
Jafrabad-II, Shahadra North Zone, Delhi-110053.

Sub:- Regarding renewal of Fire Safety Certificate in r/o M.C.D. Primary School, Jafrabad-II, Shahadra North Zone, Delhi-110053.


Sir,

Please refer to your letter No. DDO/Sch/Tbd-2/2025/D-137 dated 22/05/2025 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 29/05/2025 in the presence of Mr. Moh. Nazim (Principal) and observed that the shortcomings issued by this department vide letter No. F6/DFS/MS/School/2015/1885 dated 17/08/2015. (Copy Enclosed) still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Encl: as above


26/06/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE.

Copy to:-

1. The Dy. Director of Education, MCD Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi-92.

dlb

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/OFS/MS/School/2015/1885
To,

Dated: 17/08/15

The Principal (1st Shift)
EDMC Primary School,
Jafrabad, Delhi-53

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC
Primary School, Jafrabad, Delhi-53

Madam,

Please refer to your letter dated 13.07.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings:-

1. The width of main staircase is 1.35 m against the requirement width of 1.5 m and thus an additional staircase having width not less than 0.75 m is required.
2. First Aid Hose reels not provided.
3. Fire pump having capacity 450 LPM out put at 40 m head not provided.
4. Over head water storage tank 10,000 liters capacity for firefighting not provided.
5. Exit signs not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under intimation to this department for further course of action.

Yours faithfully



(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

Copy to:-

- 1 The Director of Education,
East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (2nd Shift)
EDMC Primary School, Jafrabad, Delhi-53