

C/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/ 132

Dated: 04/03/2025

To

The Principal,
MCD Primary Co-Ed School,
Kucha Moatter Khan, Mori Gate, Delhi - 06.

Sub:- Regarding renewal of Fire Safety Certificate in r/o MCD Primary Co-Ed School, Kucha Moatter Khan, Mori Gate, Delhi - 06.

Sir,

This has reference to your letter outdoor diary No. 11875 dated 28.01.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 22.02.2025 in the presence of Principal and it was observed that building is comprised of ground floor only. During the inspection, following shortcoming was observed:-

1. Fire extinguishers provided but non functional.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
SO 21/2/25

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.