



C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2025/School/594

Dated: 02/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary Co-ed School located at Majlis Park, Delhi-110033 comprised of Ground & first floor owned/occupied by North M.C. Primary Co-ed School was granted FSC by this department vide letter no. F6/DFS/MS/School/2021/206 Dated 10.03.2021. The premises was inspected by the officer concerned of this department on 21.04.2025 in presence of Smt. Madhu Bansal (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from02/05/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on02/05/2025 at New Delhi by

(Atul Garg)
Director
Ph:-011-23414000
02/05/2025

Copy to:-

1. The Dy. Director, Education Department, GNCT of Delhi, Civil Line Zone, 16 Rajpura Road, Delhi.
2. The Principal, M.C. Primary Co-ed School located at Majlis Park, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M.C Primary Co-ed School at Majlis Park, Delhi-110033.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & first floor
5. Details of previous NOC : No.F6/DFS/MS/School/2021/206 Dated 10.03.2021
6. Fire Safety directives letter No : Nil
7. Date of inspection : 21.04.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Smt. Madhu Bansal (Principal)
10. Year of Construction : 2002
11. Applicant's letter No. : Online E-Mail I.D Dated: 24.03.2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.90m & 1.40m	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m & 0.94m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	05nos	05nos	MR
	• Types	ABC/Co2	ABC-05	MR
	• ISI marking	ISI Marked	Provided	MR

9 E

N-18

6	First-Aid Hose Reels.			NA	NA	NA
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter	NA			NA	
		NA			NA	
		NA			NA	
7	Automatic fire detection and alarming system.			NA	NA	NA
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location	NA			NA	
		NA			NA	
		NA			NA	
		NA			NA	
		NA			NA	
8	MOEFA			NA	NA	NA
9	Public Address System.					
10	Automatic Sprinkler System.			NA	NA	NA
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling	NA			NA	
		NA			NA	
		NA			NA	
11	Internal Hydrants			NA	NA	NA
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA			NA	
		NA			NA	
		NA			NA	
12	Yard Hydrants.			NA	NA	NA
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA			NA	
		NA			NA	
13	Pumping Arrangements.					
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	N/A			N/A	N/A
		N/A			N/A	N/A
		N/A			N/A	N/A
		NA			NA	NA
		NA			NA	NA
		N/A			N/A	N/A
		N/A			N/A	N/A
		N/A			N/A	N/A
		NA			NA	NA
		NA			NA	NA
		NA			NA	NA
		NA			NA	NA
		14	Captive Water Storage for fire fighting.			NA
<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection➤ Fire service inlet➤ Access to tank	NA			NA		
	NA			NA		
	NA			NA		
	NA			NA		

	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular, the FSC issued vide letter of even no. F6/DFS/MS/School/2021/206 Dated 10.03.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
 Name: - C.L. Meen
 Designation: - ADO/RN

D.B. Mukharjee (DO/NW)

DCFO/1222-NW
 Dated... 23/04/2021

CFD/23/4/2021
 Director/23/4/2021

conf. - P.