



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/12

Dated: 03/01/2025

To,

The Principal,
MCD Primary Boys School,
Marginal Bandh New-II, New Seelampur,
Delhi – 110053.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary Boys School located at Marginal Bandh New-II, New Seelampur, Delhi – 110053.

Sir,

This has a reference to your outdoor dairy no. 10095 dated 09/12/2024 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 21/12/2024 in the presence of Mr. Ashok Kumar (Principal) and observed that school building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers is found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Overhead tank of 2,000 liters capacity is provided against the requirement of 10,000 liters

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal (1st Shift), MCD Primary Boys School located at Marginal Bandh New-II, New Seelampur, Delhi – 110053
3. The Principal (2nd Shift), MCD Primary Boys School located at Marginal Bandh New-II, New Seelampur, Delhi - 110053.