



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 747

Dated: 09/06/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **M.C.D. Primary Co-Ed. School** situated at Masjid Moth, New Delhi-110049 (School ID: 1959028), comprised of Ground plus one upper floor, owned/occupied by Municipal Corporation of Delhi, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/652 dated 15/06/2022. The premise was re-inspected by the officer concerned of this department on 26/05/2025 in the presence of Sh. Prem Singh (Teacher) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular No. 3298 to 3398 dated 01/03/2011 and that the said premises/building is fit for occupancy class "Educational Group B" with effect from 09/06/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/06/2025 at New Delhi by


61/61/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, MCD, Civic Centre, Minto Road, New Delhi-110002.
2. The Principal, MCD Primary Co-Ed. School at Masjid Moth, New Delhi-110049

Condition for the validity of fire safety certificate:

- 1 The stairs/ passage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 4 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 5 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
- 6 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of DFS Rules, 2010, form is available on www.dfs.delhigovt.nic.in.

N-13

INSPECTION REPORT				
1.	Name & address of the building	M.C.D. Primary Co-Ed. School, Masjid Moth, New Delhi-110049 (School ID: 1959028)		
2.	Building comprised of	Ground + 01 upper floor.		
3.	Type of occupancy	Educational		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2022/SZ/652 Dt. 15/06/2022		
6.	Fire Safety directives letter No.	DOE Circular No. 3298 to 3398 dated 01/03/2011		
7.	Date of Inspection	26/05/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side.	Ms. Prem Singh (Teacher)		
10.	Year of construction	2007		
11.	Applicant's letter No.	Outdoor diary No 604 dated 15/04/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirement U/R 35(6)	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	4 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	02 Nos	Provided	MR
	➤ Basements	N/A	N/A	N/A
	b. Width of staircases			
	➤ Upper floors	1.50m/0.75m	1.50m & 1.30m	MR
	➤ Basements	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 No	Provided	MR
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers at each floor	04 Nos	04 Nos	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

JK

N-14

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

84

N-15

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under DOE Circular, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/652 dated 15/06/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

CFO (MS)

3/6/2025

DO (AP/CO)

ADO (SJ)

Sir,

F.T. letter is put up for perusal.

CFO (MS)

3/6/2025

M. S. Ull

Signature
3/6/25