

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 /School/WZ/ 650

Dated 13/05/2025

FIRE SAFETY CERTIFICATE

Issued on ... 3. 6.5. 2.625. at New Delhi by

(Atul Garg) Director Ph. 011-23414000

all

## Copy to:-

1. The Director, Education, MCD, Civic Center, Delhi.

2. The Principal, MCD Primary Girls School located at Palla, Delhi-110036.

## Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT Name & address of the building :

MCD Primary Girls School located at Palla, Delhi- 110036. Educational

Ground floor only Renewal

 Name & address of the building
 Type of Occupancy
 Building Comprised of
 Type of Case
 Details of Previous NOC
 Fire Safety directives letter No F6/DFS/MS/2022/School/WZ/239 dated 07/03/2022 DOE circular No. 3298-3398 dated 01/03/2011 7. Date of inspection 02/05/2025

R.K.Sinha, ADO (BW)

8. Name of Inspection Officer

9. Name and designation of officers
From the building side

10. Year of Construction Smt. Babli (In-charge)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Outdoor Diary No. 1114  DOE	Provided at site	Remarks		
l	Access to building	Requirement		MR/NMR		
	Road width					
	Gate width	6 m	Provided	MR		
	Width of internal road	4.5 m	3.45 m	MR(old case		
2.	Number, Width, Type & Arrangeme	NA ent of Exits	NA	NA		
	Number of staircases					
	Upper Floors	NA				
	Basements	NA	NA	NA		
	Width of staircases	NA	NA	NA		
	100 To 1000					
	Upper Floor	NA	NA	NA		
	Basements	NA	NA	NA		
	Protection of exits					
	Fire check door	NA	NA	NA		
	Pressurization	NA	NA	NA		
	No. of continuous staircases to terrace	NA	NA	NA		
	Width of Corridor	NA	NA	NA		
	Door Size	1 m	Provided	MR		
3.	Compartmentation					
	Fire check door	NA	NA	NA		
	Sealing of electrical shafts	NA	NA	NA		
	Fire Rating of shaft door	NA NA	#2227 L			
	Water Curtain	NA NA	NA NA	NA		
		NA NA		NA		
4.	Fire Dampers NA NA NA Smoke Management System					
***	Basements	NA	N/A			
		500,040,050	NA	NA		
	Upper floors	NA	NA	NA		
5.	Fire Extinguishers					
	Total numbers	03	04	MR		
	Types	ABC / CO2Type	Provided	MR		
	IS marking	Required	Provided	MR		
6.	First-Aid Hose Reels					
	Total numbers on each floor	NA	NA	NA		
	Length of hose reel hose	NA NA	NA	NA		
	Nozzle diameter	NA	NA	NA		
7.	Automatic fire detection and alarming system					
	Type of detectors	NA	NA	NA		
	Location of Main Panel	NA	NA	NA		
	Location of Repeater Panel	NA	NA	NA NA		
	Alternate source of power	NA	NA	NA NA		
		NA				
	Hooters' Location		NA	NA		

		10		NA System Battery Pac		
8.	MOEFA	N-19		NA A		
9.	Public Address System	NA NA	NA NA	NA NA		
10.	Automatic Sprinkler System	NA NA	INA	/,		
	Basement	NA	NA	NA NA		
	Ground Floor	NA NA	NA NA	NA		
	Sprinkler above false ceiling	NA NA	NA NA	NA		
11.	Internal Hydrants					
	Size of size //	NA				
	Size of riser/down-comer	NA	NA	NA NA		
	Number of hydrants per floor Hose Box	NA	NA	NA NA		
12.	Yard Hydrants	NA	NA	NA		
				/		
	Total number of hydrants Hose Box	NA	NA	NA		
13.	Pumping Arrangements	NA	NA	NA		
98550						
	Ground Level					
	Discharge of main Pump	NA	NIA	NA		
	Head of Main pump	NA NA	NA NA	NA NA		
			IVA.			
	Number of main pumps Jockey Pump out put	NA	NA	NA -		
	Jockey pump head	NA	NA	NA		
	Standby Pump out put	NA	NA	NA		
	Standby Pump Out put Standby Pump Head	NA	NA	NA		
	Auto Starting/Manual Stopping	NA	NA	NA		
		NA	NA	NA		
	Pump House Access	NA	NA	NA		
	Terrace level		A.			
	Discharge of pump	w <sup>14</sup>				
	Head of the pump	NA NA	NA NA	NA		
		· · ·	NA	NA		
	Power Supply	NA	NA	NA		
14.	Auto Starting of pump	NA	NA	NA NA		
•	Captive Water Storage for fire fighti					
	Underground tank capacity	` NA	, NA	NA		
	Draw-off connection	' NA	\NA	NA NA		
	Fire service inlet	NA	NA NA	NA NA		
	Access to tank	NA	NA	NA NA		
	Overhead Tank capacity	NA	NA			
5.	Exit Signage.	NA	NA NA	NA NA		
6.	Provision of Lifts.		CAMAC TA			
	Pressurization of Lift Shaft	NA	NA	NTA		
	Pressurization of Lift lobby	NA	NA NA	NA		
	Communication In lift Car	NA NA	NA NA	NA		
	Fireman's Grounding Switch	NA		NA		
	Lift Signage	NA NA	、 NA、	NA		
7.	Standby power supply	2000	NA	NA		
	1	NA	NA	NA		
18.	Refuge Area.					
	Total Area	NA	NA			
	Location	NA NA	NA NA	NA		
9.	Fire Control Room	200000	NA	NA		
	Detector Sustant Barri			1		
	Detector System Panel	NA	NA	NA.		
		ev/				

Switch Panel	NA	NA	T 374
	NA	NA	NA
PPA System Panel	· · · · · · · · · · · · · · · · · · ·		NA
Variation backup	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans  Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found

functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/239 dated 07/03/2022.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

Diverson

06/05/2025

M FIT Just in Broto for compleys