

CP

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SZ/2025/ 136/

Dated: 28/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of MCD Primary Model School (Boys) Located at Pochan Pur, New Delhi – 110077, having three blocks Block A & Block C comprised of ground floor only & Block B comprised of Ground + One Upper Floor was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2022/SZ/932 Dated 01/09/2022. The premise was re inspected by the officer concerned of this department on 19/11/2025 in the presence of Ms. Savita Sharma (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 28/11/2025 for a period of three years.

Issued on .. 28/11/2025 .. at New Delhi by.

  
(A.K. Malik)  
Dy. Chief Fire Officer  
South Zone  
9/11/25

Copy to: -

1. The Principal, MCD Primary Model School (Boys) Located at Pochan Pur, New Delhi – 110077. (School ID-1757195)
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/12

**INSPECTION REPORT**

1. Name & address of the building: MCD Primary Model School (Boys)  
Located at Pochan Pur, New Delhi - 110077. (School ID-1757195)
2. Type of Occupancy : Educational( 02 Blocks A & C- Ground Floor & 01 Block B- G+1 UF's)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2022/S7/932 Dated 01/09/2022
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 19/11/2025
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Savita Sharma (Principal)
9. Year of Construction : 2010
10. Applicant's letter No. : Nil dated 15/10/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per FSC dated- 01/09/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 mtr Accessible NA	Provided 3.75 mtr NA	MR MR (Being old case) NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	02 Nos. in B block NA	2 Provided NA	MR NA
	b. Width of staircases <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	150cm NA	1.40 m & 1.45 m NA	MR (Being old case) NA
	c. Protection of exits <ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace <ul style="list-style-type: none"> <li>Width Of Corridor</li> </ul>	NA 1m	150cm 1m	NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA



4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	10 Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
		NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

