



No. F6/DFS/MS/School/NDZ/2025/ 184

Dated: 03/04/2025

To,

The Principal,
MCD Primary School,
Rajiv Nagar - II, Delhi – 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Rajiv Nagar - II, Delhi – 110094.

Sir,

This has a reference to your letter diary no.14532 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/03/2025 in the presence of Manager and observed that building comprised of Two blocks, Ground + One upper floor only (Block A) & Ground + Three upper floors (Block B)

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.46 meter are provided against requirements of 1.50 meters each in block B.
2. First-Aid-Hose Reel at not provided.
3. Fire pump of 450 LPM not provided.
4. Overhead tank of 10,000 liters capacity not provided.
5. Exit & floors Signage's found removed in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

OK (u) DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.