

C-10



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/School/NDZ/2025/186

Dated: 03/04/2025

To,

The Principal,  
MCD Primary School (English Medium),  
Shriram Colony-II, Rajiv Nagar, Shahdara, Delhi - 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School (English Medium), located at Shriram Colony-II, Rajiv Nagar, Shahdara, Delhi – 110094**

Sir,

This has a reference to your letter diary no.14522 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/03/2025 in the presence of Manager and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel at provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Over head water storage tank of capacity 6,000 litr. provided against requirement of 10,000 litr.
4. Exit & floors Signage's found removed in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

OK DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.