



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

DFAT-15  
C-17  
75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/SCHOOL/NDZ/2025/ 183

Dated: 03 / 4 / 2025

To,

The Principal,  
MCD Primary School  
Sadat Pur (II), Shahdara North,  
Delhi – 110094.

**Subject: - Regarding Grant of Fire Safety Certificate in r/o MCD Primary School located at Sadat Pur (II), Shahdara North, Delhi – 110094.**

Sir,

Please refer to your letter email dated 15/03/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 25/03/2025 and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/School/2021/346 dated 14/07/2021 (copy enclosed).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: As above

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi - 110092.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

Dated: 14/07/2021

No. F6/DFS/MS/School/2021/ 346

To,

The Principal,  
EDMC Nigam Pratibha Vidyalaya,  
Sadatpur (II) Shahdara North,  
Delhi 110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o EDMC Nigam Pratibha Vidyalya, Sadatpur (II) Shahdara North, Delhi 110094.

Sir,

With reference to your email letter No. nil dated 17/03/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Manoj, Teacher of the School to verify the compliance of shortcomings already communicated by this department vide letter No. F6/DFS/MS/School/2013/2528 dated 14/11/13 and was observed that following shortcomings have not been complied.

1. First Aid Hose reel not provided.
2. A fire pump having 450 LPM output at 40 meters head not provided.
3. Over head tank 10,000 liter not provided.
4. Exit signage not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

The Director of Education, EDMC  
Udyog Sadan, Plot No. 419, FIE,  
Patparganj, Delhi 92