



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ WZ / 1308

Dated: 12/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M.C.D. Primary (Boys) School located Sector-4-II, Rohini, Delhi-110085 comprised of Single Block (old), Ground & First Floor owned/ occupied by M.C.D. Primary (Boys) School was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/2022/School/WZ/974 dated 06/09/2022. The premises was inspected by the officer concerned of this department on 01/11/2025 in presence of Sh. Deepak Sharma (Incharge) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School) for ground & first floor only" with effect from .....12/11/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on .....12/11/2025..... at New Delhi by.

*(S.K. Dua)*

Dy. Chief Fire Officer  
 Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, MCD, Zonal Office, First Floor, Sector-5, Rohini Zone, Delhi - 110085.
2. The Incharge, M.C.D. Primary (Boys) School located Sector-4-II, Rohini, Delhi-110085.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/14

**INSPECTION REPORT**

1. Name & address of the building : M. C. D. Primary (Boys) School, Sector-4-II, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & First Floor only
5. Details of Previous NOC : F6/DFS/MS/2022/School/WZ/974 dated 06/09/2022.
6. Fire Safety directives letter No : Nil
7. Date of inspection : 01/11/2025
8. Name of Inspecting Officer : ADO (Rohini)
9. Name and designation of officers  
From the building side : Sh. Deepak Sharma (Incharge)
10. Year of Construction : 2003
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No. 6350 dated 23/09/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible Accessible NA	Accessible 3.70m NA	MR MR(Old case) NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	01 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.5m NA	1.5m & 01m NA	MR NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m double door	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA Required	NA Natural ventilated	NA MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	08nos. ABC/CO2 ISI marked	Provided Provided Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA NA NA	NA NA NA	NA NA NA

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

N/16

	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Note:-

The school management has requested to renewal of Fire Safety Certificate for old block ground & first floor only. We may consider the request, if agreed please.

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is **recommended for renewal of fire safety certificate** issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/974 dated 06/09/2022.

Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO (Rohini)

DONW

3.11.2025

Dy CFO (WZ)

Principal Director

Kimp

Dy. CFO to Meena

Dy. CFO (WZ)

F.T. please.

ADO (Rohini)

Kimp

As approved, F.T. letter is put up for your signature please.

Dy CFO (WZ)

Kimp

F.P. wing

10/11/2025