



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 660

Dated: 20 / 08 / 2025

To

Mrs. Raj Bala (Principal),
MCD Primary School,
Sector-I/II, Dwarka,
New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o MCD Primary School located at Dwarka, Sector-I/II, New Delhi-110075**

Madam,

This is with reference to e-mail received from Id. mcpsdwarkasector2@gmail.com dated 08/07/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 23/07/2025 in your presence from fire safety point. **During the course of inspection, the shortcomings observed are as below: -**

1. Hose reel hose system provided found non-functional.
2. Terrace level fire pump found non-functional.
3. Overhead water storage tank for exclusive for fire-fighting found empty.
4. Exit signage's in escape route found removed at some locations.

In view of the above non-compliance, renewal of **fire safety certificate cannot be considered at this stage**. You are requested to rectify the above shortcomings under intimation mentioned to this department for further action in the matter.

Yours faithfully,


19/8/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Municipal Corporation of Delhi, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002