



75
Azadi Ka
Amrit Mahotsav

C/36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 517

Dated: 10 /06 /2025

To

Mrs. Nirmala (Principal),
MCD Primary Co-Ed. School,
Sewa Nagar (East),
New Delhi-110003

Sub: **Regarding renewal of Fire Safety Certificate in r/o MCD Co-Ed. Primary School at
Sewa Nagar (East), New Delhi 110003 (School ID: 1958005)**

Sir,

This has a reference to your letter No. Nil dated 07/03/2025, received in this department vide outdoor diary No. 14211 dated 07/03/2025, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on 26/05/2025 in your presence. During course of inspection, the shortcomings observed are as below: -

1. Terrace pump found non-functional.
2. Overhead water storage tank found removed.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are advised to submit compliance of the shortcomings for further action in the matter.

Yours faithfully,


9/6/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
9/6/25

Copy to: -

1. The Director of Education, MCD, Civic Centre, Minto Road, New Delhi-110002