



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

4/19  
सत्यमेव जयते

No.F.6/DFS/MS/School/2025/NDZ/ 502

Dated: 09/6/2025

To,  
The Manager,  
M.C.D. Primary School  
L-Block, Sunder Nagri,  
Delhi-110093

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M.C.D. Primary School located at L-Block, Sunder Nagri, Delhi-110093.**

Sir,

This is in reference to your letter no. nil dated 17/04/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 27/05/2025 in presence of Mr. Virendra Kumar and observed that the management has still not complied the shortcoming by this department vide letter No. F.6/DFS/MS/2019/NDZ/7045 dated 26/11/2019 (copy enclosed).

In view of the above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours faithfully

*Virendra Singh*  
6/6/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER

Encl. As above

Copy to:-

The Director of Education (MCD)  
15<sup>th</sup> Floor, E-Block, Dr. S.P. Mukahrjee Civic Center, JLN Marg, New Delhi-110002

8 C/18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2019/NDZ/ 7045

Dated 26/11/19

To,

The Principal,  
EDMC Primary School,  
L-Block, Sunder Nagri,  
Delhi-110093

**Sub:- Regarding Fire Safety Certificate.**


Sir,

With reference to your letter on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Savita Arora, Principal of the School on dated 19/10/2019. The School building comprises of ground plus first floor. During the course of inspection following observation was made:-

1. The school is not accessible to fire engines as road width is less than 6 meters.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer

Copy to:-

The Director of Education, EDMC  
Udyog Sadan, Plot No. 419, FIE,  
Patparganj, Delhi -92

ofc J.S.