

208

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2025/ 822

Dated: - 19/11/2025

To,

The In-charge,  
MCD Primary School,  
Than Singh Nagar- I,  
Karol Bagh, New Delhi-110005.

Sub: - Regarding issuance of "Fire Safety Certificate" in r/o M.C.D. Primary School at Than Singh Nagar- I, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to your letter No. Nil, dated Nil, received in this office through outdoor dairy No. 7082 dated 15.10.2025, on the subject cited above. In this connection it is to inform you that the above said school building have been inspected by the officer concerned of this department, in presence of Ms. Deepti (In-charge) on dated 03.11.2025, to check the status of the shortcomings already pointed out by this department vide letter No. F.6/DFS/MS/School/2013/309 dated 18.01.2013 (copy enclosed) which are still not complied.

In view of the above, issuance of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to follow the direction in to given in the letter dated 18.01.2013 (copy enclosed) under intimation to this department for taking further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully



(A.K. Malik)  
Dy. Chief Fire Officer  
South Zone

Copy to:-

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.

C-4

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No.F.6/DFS/MS/School/2013/309

Dated 18/01/13

To

The Principal  
M.C. Primary School (1st & IInd shift)  
Than Singh Nagar,  
Karol Bagh,  
New Delhi. -110005

Sub: Issuance of NOC in r/o M.C. Primary School (1st & IInd shift), Than Singh Nagar, Karol Bagh, New Delhi-110005.

Sir,

Please refer to your office letter No. Nil dated 30.11.2012 on the subject cited above. In this regard it is to inform you that the above said premises has been inspected by the officer concerned of this department on 04.01.2013 to ensure the compliance of fire safety recommendation issued vide this office letter No. F.6/DFS.MS/10/318 dated 03.02.2010. Sh. Devi Dutt was present at the time of inspection.

During the course of inspection it has been observed that the school building is comprised of ground plus two upper floors and served by single staircase having width of 108 cms. No fire safety arrangement provided in the building except few numbers of fire extinguishers. The fire safety recommendations are as under:

- 1 One Co2 type 2.5 kg cap and one DCP type 5 kg cap fire extinguishers or one water Co2 type fire extinguisher of 9 ltrs. Cap. with ISI marked shall be provided for every 300 sq.m of covered area on part there of subject to a minimum of two fire extinguishers for every floor.
- 2 The first aid hose reels are not provided.
- 3 The fire pump of 450 LPM discharge with 30 mtrs head is not provided.
- 4 The overhead water storage tank of 10000 ltrs cap. is not provided.
- 5 The staircase width is 108 cms instead of 1.50 mtrs.

In view of the above no objection certificate cannot be considered at this stage. The Management is advised to comply the above said fire safety recommendations and intimate to this department for compliance.

Yours faithfully

  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

- 1 The Director of Education  
South Delhi Municipal Corporation  
23<sup>rd</sup> floor, Dr. SPM Civic Centre,  
Minto Road Gate,  
New Delhi-110002.