

C/17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/School/2025/NDZ/496

Dated: 09 / 06 / 2025

To

The Principal
M.C.D. Pratibha School,
Urdu-1, Chauhan Banger, Delhi-110053.

**Sub.:- Regarding renewal of Fire Safety Certificate in r/o M.C.D. Pratibha School,
Urdu-1, Chauhan Banger, Delhi-110053.**

Sir,

Please refer to your letter received through email dated 29/05/2025 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 04/06/2025 in the presence of Mr. Arshad (Teacher) and observed that the shortcomings issued by this department vide letter No. F6/DFS/MS/School/2015/2122 dated 17/09/2015. (Copy Enclosed) still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: As Above


6/6/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE.

plc 

Copy to:-

1. The Dy. Director of Education, MCD Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi-92.

2/12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. *F6/AFS/MS/school/2015/2122*
To,

Dated: *17/09/15*

The Principal,
EDMC Primary School,
Chauhan Banger, Urdu-I (Shahdara North Zone), Delhi-53

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, Chauhan Banger, Urdu-I (Shahdara North Zone), Delhi-53

Madam/Sir,

Please refer to your letter no. CBU-1st /Aug-15 dated 13.08.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus one upper floor and has following shortcomings:-

1. The School is not accessible to fire engines as approach road width is less than 6 meters.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Signature)
(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

07/09/15

Copy to:-

The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92