

c/11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2025/ 447

Dated: 26/05/2025

To

The Principal,
MCD Primary Co-Ed School,
Gali Bandoor, Ajmeri Gate, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o MCD Primary Co-Ed School, Gali Bandoor, Ajmeri Gate, Delhi - 110006.

Sir,

This has reference to letter outdoor diary no. 744 dated 17.04.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 17.05.2025 in the presence of Mr. Brij Mohan (Gate Keeper) and observed that the building is comprised of ground + 02 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/NDZ/2019/School/7425 dated 12.12.2019 except following which still exists.

1. The school is not accessible to fire engines as approach road width is less than 06 meters.
2. The width of main staircase is 1.39 m against the requirement of width 1.5 m either an additional staircase is required having less than 0.75 m.
3. Fire pump not on auto start mode.
4. Exit signages are not provided.

In view of the above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

(Anu Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

21/5