

c/14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/ 450

Dated: 26/05/2025

To

The Principal,
M. C. P. Co-Ed School,
Bulbuli Khana, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M. C. P. Co-Ed School, Bulbuli Khana, Delhi - 110006.

Sir,

This has reference to your letter outdoor diary No. 657 dated 16.04.2025 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 19.05.2025 in the presence of Mrs. Sadaf Nafees (Incharge) and found that the school building is comprised of ground plus one upper floor. During the inspection, following shortcomings were observed:-

1. The school building is not accessible to fire engine.
2. An additional fire escape staircase not less than 0.75 m wide not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000

ok

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

50-6/21/5